



OFFICE OF THE DEPUTY FIRE OFFICER,  
ANGUL CIRCLE, ANGUL, PIN-759122

Tel. No: 06764- 232444, Mob No: 7655072548 (CUG) Email ID: dfoang-ofs@gov.in

FORM - V

FIRE SAFETY CERTIFICATE

(See rule-13(3) of Odisha Fire Prevention and Fire Safety Rules-2017)

File No.A-4-2020

Certificate No.28/2021 of Angul Circle

Date: 07.04.2021.

This Initial Certificate is valid up to 06.04.2023.

(Apply for renewal at least three months before expiry)

Certified that the G+2 Educational Building named as **Maharishi Vidya Mandir**, situated over Plot No.4215 & others, Mouza- Turang, Dist- Angul was inspected by a team of Officers of Odisha Fire Service on 06.04.2021 in presence of Sri Ashutosh Mishra, I/C Principal and it has been found to comply with the Fire Prevention and Safety requirements in accordance with the Odisha Fire Prevention and Fire Safety Rules-2017 read with Fire Prevention and Fire Safety (Amendment) Rules-2019 and Govt. Notification No.28550/CD, BBSR dtd.28.08.2020 and that the Educational Building is fit for occupancy or usage subject to compliance to the conditions as prescribed herein below.

CONDITIONS:-

1. Fire prevention and safety measures and appliances, availability of water supplies and means of access thereto etc provided in the building or premises, should be maintained by the occupier in best repairs and efficient working condition at all times for use by the occupants or the members of the Fire Service or both in the event of outbreak of fire.
2. The set-backs, driveways, entrance gates, exits, staircases, corridors and escape ways should not be changed, obstructed or modified in any way.
3. The occupiers shall train all staff and occupants periodically to make them well conversant in use and operation of Fire Prevention and safety measures.
4. Fire drills/Rehearsals should be organized at least once in six months by involving local Fire Station.
5. Photo copies of this Certificate should be framed and displayed at all conspicuous places in all lobbies/corridors in all floors of all Towers/Blocks of building/premises.

*07/04/2021*  
(Simanchala Padhi)

Deputy Fire Officer


Angul Circle, Angul

**Deputy Fire Officer**  
**Angul Circle, Angul**

Memo No. 534/AGL Circle

Date: 07.04.2021


Copy to Dr. Gayatree Samantaray, Principal, Maharishi Vidya Mandir, At/PO-Turang, Dist- Angul, Odisha, Pin-759123 for information and necessary action.

  
(Simanchala Padhi)  
Deputy Fire Officer  
Angul Circle, Angul

Memo No. 535/AGL Circle

Date: 07.04.2021


Copy to Station Officer, Angul Fire Station for information.

  
(Simanchala Padhi)  
Deputy Fire Officer  
Angul Circle, Angul

Memo No. 536 (2)/AGL Circle

Date: 07.04.2021

Copy submitted to Chief Fire Officer (FPW), Directorate of Fire Services, Odisha, Cuttack/Fire Officer, NR, Sambalpur for favour of kind information.

  
(Simanchala Padhi)  
Deputy Fire Officer  
Angul Circle, Angul